



BSI Standards Publication

Electric cables — Low voltage energy cables of rated voltages up to and including 450/750 V (U_0/U)

Part 2-31: Cables for general applications — Single core non-sheathed cables with thermoplastic PVC insulation

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide[™]

Copyright European Committee for Electrotechnical Standardization
Provided by IHS under license with CENELEC
No reproduction or networking permitted without license from IHS

Not for Resale

National foreword

This British Standard is the UK implementation of EN 50525-2-31:2011.

In the UK, the BS EN 50525 series of standards contain complex supersession details. The table below best summarizes the relationship between these standards:

Part 1 together with	Supersedes
2-81	BS 638-4:1996
2-41, 2-42	BS 6007: 2006
2-11 (in part), 2-12, 2-21 (in part), 2-71	BS 6500:2000
2-11 (in part), 2-21 (in part), 2-51 (in part), 2-83, 3-21	BS 7919:2001
2-31, 2-51 (in part)	BS 6004:2000
3-41	BS 7211:1998
2-22, 2-72, 2-82, 3-11, 3-31	None

NOTE All British Standards will remain current until they are withdrawn on 31 December 2012. British Standards in bold are only partially superseded, and new editions of BS 6004 and BS 7211 will be introduced on 1 January 2013.

National Annex NA (informative) gives information on the origins and identification of particular cable types.

The UK participation in its preparation was entrusted to Technical Committee GEL/20/17, Electric Cables - Low voltage.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2011

ISBN 978 0 580 64366 8

ICS 29.060.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2011.

Amendments issued since publication

Date	Text affected
------	---------------

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50525-2-31

May 2011

ICS 29.060.20

Supersedes HD 21.3 S3:1995 + A1:1999 + A2:2008, HD 21.7 S2:1996 + A1:1999

English version

**Electric cables -
Low voltage energy cables of rated voltages up to and including 450/750 V
(U_0/U) -
Part 2-31: Cables for general applications -
Single core non-sheathed cables with thermoplastic PVC insulation**

Câbles électriques -
Câbles d'énergie basse tension de tension
assignée au plus égale à 450/750 V
(U_0/U) -
Partie 2-31: Câbles pour applications
générales -
Conducteurs isolés en PVC
thermoplastique

Kabel und Leitungen -
Starkstromleitungen mit Nennspannungen
bis 450/750 V (U_0/U) -
Teil 2-31: Starkstromleitungen für
allgemeine Anwendungen -
Ader- und Verdrahtungsleitungen mit
thermoplastischer PVC-Isolierung

This European Standard was approved by CENELEC on 2011-01-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

© 2011 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 50525-2-31:2011 E

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 20, Electric cables.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50525-2-31 on 2011-01-17.

This document, which is one of a multipart series, supersedes HD 21.3 S3:1995 + A1:1999 + A2:2008 and HD 21.7 S2:1996 + A1:1999.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2012-01-17
 - latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2014-01-17
-

Contents

	Page
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 General purpose cable	5
4.1 Cables for fixed wiring – H07V-U and H07V-R	5
4.2 Cables for fixed wiring – H07V-K.....	5
4.3 Cables for internal wiring – H05V-U and H05V-R	6
4.4 Cables for internal wiring – H05V-K	6
5 Heat resistant cables (90 °C)	7
5.1 Cables for fixed wiring – H07V2-U and H07V2-R.....	7
5.2 Cables for fixed wiring – H07V2-K.....	8
5.3 Cables for internal wiring – H05V2-U and H05V2-R	8
5.4 Cables for internal wiring – H05V2-K.....	9
Annex A (normative)	10
Tests for cables to EN 50525-2-31	10
Annex B (normative)	11
General data	11
Bibliography	14

Tables

Table A.1	10
Table B.1 — Cables with rigid conductor (450/750 V)	11
Table B.2 — Cables with flexible conductor (450/750 V).....	12
Table B.3 — Cables with rigid conductor (300/500 V)	12
Table B.4 — Cables with flexible conductors (300/500 V)	13

1 Scope

EN 50525-2-31 applies to non-sheathed single core cables insulated with thermoplastic (PVC) insulation.

The cables are of rated voltages U_0/U up to and including 450/750 V.

The cables are intended for fixed wiring applications.

NOTE 1 Cables rated 450/750 V may be used at 600/1 000 V when this cable is used in fixed installations with mechanical protection, within switchgear and control gear - see HD 516.

The maximum conductor operating temperatures for the cables in this standard are 70 °C (V types) and 90 °C (V2 types).

NOTE 2 HD 516 contains extensive guidance on the safe use of cables in this standard.

This EN 50525-2-31 should be read in conjunction with EN 50525-1, which specifies general requirements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE One or more references to the standards below are in respect of a specific sub-division of that standard, for instance a clause, a table, a class or a type. Cross-references to these standards are undated and, at all times, the latest version applies.

EN 50363-3	Insulating, sheathing and covering materials for low voltage energy cables - Part 3: PVC insulating compounds
EN 50395	Electrical test methods for low voltage energy cables
EN 50396	Non electrical test methods for low voltage energy cables
EN 50525-1	Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (U_0/U) - Part 1: General requirements
EN 60228	Conductors of insulated cables (IEC 60228)
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60811-1-4	Insulating and sheathing materials of electric and optical cables - Common test methods - Part 1-4: General application - Tests at low temperature (IEC 60811-1-4:1985 + A1:1993 + corr. May 1986)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in Clause 3 of EN 50525-1 apply.

4 General purpose cable

4.1 Cables for fixed wiring – H07V-U and H07V-R

4.1.1 Construction

4.1.1.1 Conductor

The conductor shall be class 1 or class 2, according to EN 60228.

4.1.1.2 Sizes of cable

The sizes of cable shall be:

- class 1 – 1,5 mm² to 10 mm²;
- class 2 – 1,5 mm² to 1 000 mm².

4.1.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 1 to EN 50363-3 applied around the conductor.

4.1.1.4 Marking

The cable shall be marked with the CENELEC code H07V-U for cables with class 1 conductor, or H07V-R for cables with class 2 conductor. The marking shall comply with Clause 6 of EN 50525-1.

4.1.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 6.

The dimensions of the cables shall conform to Table B.1 for the relevant size.

4.2 Cables for fixed wiring – H07V-K

4.2.1 Construction

4.2.1.1 Conductor

The conductor shall be class 5 according to EN 60228.

4.2.1.2 Sizes of cable

The sizes of cable shall be 1,5 mm² to 240 mm².

4.2.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 1 to EN 50363-3 applied around the conductor.

4.2.1.4 Marking

The cable shall be marked with the CENELEC code H07V-K. The marking shall comply with Clause 6 of EN 50525-1.

4.2.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 7.

The dimensions of the cables shall conform to Table B.2 for the relevant size.

4.3 Cables for internal wiring – H05V-U and H05V-R

4.3.1 Construction

4.3.1.1 Conductor

The conductor shall be class 1 or class 2, according to EN 60228.

4.3.1.2 Sizes of cable

The sizes of cable shall be:

- class 1 – 0,5 mm² to 1 mm²;
- class 2 – 0,5 mm² to 1 mm².

4.3.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 1 to EN 50363-3 applied around the conductor.

4.3.1.4 Marking

The cable shall be marked with the CENELEC code H05V-U for cables with class 1 conductor, or H05V-R for cables with class 2 conductor. The marking shall comply with Clause 6 of EN 50525-1.

4.3.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 8.

The dimensions of the cables shall conform to Table B.3 for the relevant size.

4.4 Cables for internal wiring – H05V-K

4.4.1 Construction

4.4.1.1 Conductor

The conductor shall be class 5 according to EN 60228.

4.4.1.2 Sizes of cable

The sizes of cable shall be 0,5 mm² to 1 mm².

4.4.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 1 to EN 50363-3 applied around the conductor.

4.4.1.4 Marking

The cable shall be marked with the CENELEC code H05V-K. The marking shall comply with Clause 6 of EN 50525-1.

4.4.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 9.

The dimensions of the cables shall conform to Table B.4 for the relevant size.

5 Heat resistant cables (90 °C)

5.1 Cables for fixed wiring – H07V2-U and H07V2-R

5.1.1 Construction

5.1.1.1 Conductor

The conductor shall be class 1 or class 2, according to EN 60228.

5.1.1.2 Sizes of cable

The sizes of cable shall be:

- class 1 – 1,5 mm² to 10 mm²;
- class 2 – 1,5 mm² to 35 mm².

5.1.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 3 to EN 50363-3 applied around the conductor.

5.1.1.4 Marking

The cable shall be marked with the CENELEC code H07V2-U for cables with class 1 conductor, or H07V2-R for cables with class 2 conductor. The marking shall comply with Clause 6 of EN 50525-1.

5.1.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 10.

The dimensions of the cables shall conform to Table B.1 for the relevant size.

5.2 Cables for fixed wiring – H07V2-K

5.2.1 Construction

5.2.1.1 Conductor

The conductor shall be class 5 according to EN 60228.

5.2.1.2 Sizes of cable

The sizes of cable shall be 1,5 mm² to 35 mm².

5.2.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 3 to EN 50363-3 applied around the conductor.

5.2.1.4 Marking

The cable shall be marked with the CENELEC code H07V2-K. The marking shall comply with Clause 6 of EN 50525-1.

5.2.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 11.

The dimensions of the cables shall conform to Table B.2 for the relevant size.

5.3 Cables for internal wiring – H05V2-U and H05V2-R

5.3.1 Construction

5.3.1.1 Conductor

The conductor shall be class 1 or class 2, according to EN 60228.

5.3.1.2 Sizes of cable

The sizes of cable shall be:

- class 1 – 0,5 mm² to 1 mm²;
- class 2 – 0,5 mm² to 1 mm².

5.3.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 3 to EN 50363-3 applied around the conductor.

5.3.1.4 Marking

The cable shall be marked with the CENELEC code H05V2-U for cables with class 1 conductor, or H05V2-R for cables with class 2 conductor. The marking shall comply with Clause 6 of EN 50525-1.

5.3.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 12.

The dimensions of the cables shall conform to Table B.3 for the relevant size.

5.4 Cables for internal wiring – H05V2-K

5.4.1 Construction

5.4.1.1 Conductor

The conductor shall be class 5 according to EN 60228.

5.4.1.2 Sizes of cable

The sizes of cable shall be 0,5 mm² to 1 mm².

5.4.1.3 Insulation

The insulation shall be polyvinyl chloride compound of Type TI 3 to EN 50363-3 applied around the conductor.

5.4.1.4 Marking

The cable shall be marked with the CENELEC code H05V2-K. The marking shall comply with Clause 6 of EN 50525-1.

5.4.2 Requirements

Each cable shall comply with the appropriate requirements given in EN 50525-1, and the particular requirements of this Part.

Testing shall be in accordance with Annex A, and the relevant tests indicated in column 13.

The dimensions of the cables shall conform to Table B.4 for the relevant size.

Annex A
(normative)

Tests for cables to EN 50525-2-31

Table A.1

1 Ref No.	2 Tests ^a	3 Cate- gory of test	4 Test method described in EN	5 Clause						6-13 Applicability of test – Subclause								
				4.1	4.2	4.3	4.4	4.5	4.6	4.7	4.8	4.9	4.10	4.11	4.12	4.13		
1	Electrical tests^b																	
1.1	Resistance of conductors	T, S	50395	5	X	X	X	X	X	X	X	X	X	X	X	X	X	X
1.2.1	Voltage test at 2 500 V	T, S	50395	6	X	X	-	-	-	X	X	X	X	X	X	X	X	X
1.2.2	Voltage test at 2 000 V	T, S	50395	6	-	-	X	X	X	X	X	X	X	X	X	X	X	X
1.3	Insulation resistance - at 70 °C - at 90 °C	T, S	50395	8.1	X	X	X	X	X	X	X	X	X	X	X	X	X	X
1.4	Long term resistance of insulation to d.c.	T	50395	9	-	-	X	X	X	X	X	X	X	X	X	X	X	X
1.5	Absence of faults in insulation	R	50395	10	X	X	X	X	X	X	X	X	X	X	X	X	X	X
2	Constructional and dimensional tests																	
2.1	Checking of compliance with constructional provisions	T, S	50525-1	Inspection and manual tests	X	X	X	X	X	X	X	X	X	X	X	X	X	X
2.2	Measurement of thickness of insulation	T, S	50396	4.1	X	X	X	X	X	X	X	X	X	X	X	X	X	X
2.3	Measurement of overall diameter	T, S	50396	4.4	X	X	X	X	X	X	X	X	X	X	X	X	X	X
3	Insulation material tests	T	50363-3 ^c	-	X	X	X	X	X	X	X	X	X	X	X	X	X	X
4	Impact test at - 5 °C	T	60811-1-4	8.5	X	X	X	X	X	X	X	X	X	X	X	X	X	X
5	Test under fire conditions	T	60332-1-2	-	X	X	X	X	X	X	X	X	X	X	X	X	X	X

^a The order given does not imply a sequence of testing.

^b Particular test conditions and requirements are given in Table 1 of EN 50525-1.

^c This EN includes all the test methods and requirements for the material. Material to be tested is taken from the finished cable.

Annex B (normative)

General data

NOTE 1 The overall dimensions of cables have been calculated in accordance with EN 60719.

NOTE 2 Cables designated "-U" have class 1 conductors, "-R" have class 2 conductors and "-K" have class 5 conductors.

Table B.1 — Cables with rigid conductor (450/750 V)

1 Nominal cross-sectional area of conductors ^a mm ²	2 Class of conductor (EN 60228)	3 Thickness of insulation Specified value mm	4 Mean overall diameter		6 Minimum insulation resistance at rated temperature MΩ.km
			Lower limit mm	Upper limit mm	
			1,5	1	
2,5	1	0,8	3,2	3,9	0,010
4	1	0,8	3,6	4,4	0,008 7
6	1	0,8	4,1	5,0	0,007 4
10	1	1,0	5,3	6,4	0,007 2
1,5	2	0,7	2,7	3,3	0,010
2,5	2	0,8	3,3	4,0	0,009 9
4	2	0,8	3,8	4,6	0,008 2
6	2	0,8	4,3	5,2	0,007 0
10	2	1,0	5,6	6,7	0,006 7
16	2	1,0	6,4	7,8	0,005 6
25	2	1,2	8,1	9,7	0,005 3
35	2	1,2	9,0	10,9	0,004 6
50	2	1,4	10,6	12,8	0,004 6
70	2	1,4	12,1	14,6	0,004 0
95	2	1,6	14,1	17,1	0,003 9
120	2	1,6	15,6	18,8	0,003 5
150	2	1,8	17,3	20,9	0,003 5
185	2	2,0	19,3	23,3	0,003 5
240	2	2,2	22,0	26,6	0,003 4
300	2	2,4	24,5	29,6	0,003 3
400	2	2,6	27,5	33,2	0,003 1
500	2	2,8	30,5	36,9	0,003 0
630	2	2,8	34,0	41,1	0,002 7
800	2	2,8	37,8	45,7	0,002 4
1 000	2	3,0	42,1	51,0	0,002 3

^a Not all cable types are specified in all the sizes given here. See the specific clause of the standard, and also of Clause 1 of EN 50525-1.

Table B.2 — Cables with flexible conductor (450/750 V)

1	2	3	4	5
Nominal cross-sectional area of conductors ^a (Class 5) mm ²	Thickness of insulation Specified value mm	Mean overall diameter		Minimum insulation resistance at rated temperature MΩ.km
		Lower limit mm	Upper limit mm	
1,5	0,7	2,8	3,4	0,010
2,5	0,8	3,4	4,1	0,009 5
4	0,8	3,9	4,8	0,007 8
6	0,8	4,4	5,3	0,006 8
10	1,0	5,7	6,8	0,006 5
16	1,0	6,7	8,1	0,005 3
25	1,2	8,4	10,2	0,005 0
35	1,2	9,7	11,7	0,004 3
50	1,4	11,5	13,9	0,004 2
70	1,4	13,2	16,0	0,003 6
95	1,6	15,1	18,2	0,003 6
120	1,6	16,7	20,2	0,003 2
150	1,8	18,6	22,5	0,003 2
185	2,0	20,6	24,9	0,003 2
240	2,2	23,5	28,4	0,003 1

^a Not all cable types are specified in all the sizes given here. See the specific clause of the standard, and also Clause 1 of EN 50525-1.

Table B.3 — Cables with rigid conductor (300/500 V)

1	2	3	4	5	6
Nominal cross-sectional area of conductor mm ²	Class of conductor (EN 60228)	Thickness of insulation Specified value mm	Mean overall diameter		Minimum insulation resistance at rated temperature MΩ.km
			Lower limit mm	Upper limit mm	
0,5	1	0,6	1,9	2,3	0,014
0,75	1	0,6	2,1	2,5	0,013
1	1	0,6	2,2	2,7	0,011
0,5	2	0,6	2,0	2,4	0,014
0,75	2	0,6	2,2	2,6	0,012
1	2	0,6	2,3	2,8	0,011

Table B.4 — Cables with flexible conductors (300/500 V)

1	2	3	4	5
Nominal cross-sectional area of conductors (Class 5) mm ²	Thickness of insulation Specified value mm	Mean overall diameter		Minimum insulation resistance at rated temperature MΩ.km
		Lower limit mm	Upper limit mm	
0,5	0,6	2,1	2,5	0,013
0,75	0,6	2,2	2,7	0,011
1	0,6	2,4	2,8	0,010

www.bsigroup.com/standards

Bibliography

- | | |
|----------|--|
| EN 60719 | Calculation of the lower and upper limits for the average outer dimensions of cables with circular copper conductors and of rated voltages up to and including 450/750 V (IEC 60719) |
| HD 516 | Guide to use of low voltage harmonized cables |

National Annex (informative) Origins and identification of the particular cable types

As an aid to users, the table below shows, in respect of BS EN 50525-2-31:

- the identification of the particular cable types from BS 6004 that are now included in BS EN 50525-2-31;
- the location of the cables within BS EN 50525-2-31;
- any applicable United Kingdom and CENELEC cable codings (see also National Informative Annex B to BS EN 50525-1).

Pre-existing BS		Clause in BS EN 50525-2-31	Cable type – Coding	
Number	Table		United Kingdom (if applicable)	CENELEC
BS 6004	4a)	4.1	6491X	H07V-U
			6491X	H07V-R
BS 6004	4b)	4.2	6491X	H07V-K
BS 6004	5	4.3	2491X	H05V-U
			2491X	H05V-R
		4.4	2491X	H05V-K
BS 6004	11a)	5.1	6491X HR	H07V2-U
			6491X HR	H07V2-R
BS 6004	11b)	5.2	6491X HR	H07V2-K
BS 6004	12	5.3	2491X HR	H05V2-U
			2491X HR	H05V2-R
		5.4	2491X HR	H05V2-K

British Standards Institution (BSI)

BSI is the independent national body responsible for preparing British Standards and other standards-related publications, information and services.

It presents the UK view on standards in Europe and at the international level.

It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

BSI offers Members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Tel: +44 (0)20 8996 7669 Fax: +44 (0)20 8996 7001

Email: plus@bsigroup.com

Buying standards

You may buy PDF and hard copy versions of standards directly using a credit card from the BSI Shop on the website www.bsigroup.com/shop. In addition all orders for BSI, international and foreign standards publications can be addressed to BSI Customer Services.

Tel: +44 (0)20 8996 9001 Fax: +44 (0)20 8996 7001

Email: orders@bsigroup.com

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Knowledge Centre.

Tel: +44 (0)20 8996 7004 Fax: +44 (0)20 8996 7005

Email: knowledgecentre@bsigroup.com

Various BSI electronic information services are also available which give details on all its products and services.

Tel: +44 (0)20 8996 7111 Fax: +44 (0)20 8996 7048

Email: info@bsigroup.com

BSI Subscribing Members are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.

Tel: +44 (0)20 8996 7002 Fax: +44 (0)20 8996 7001

Email: membership@bsigroup.com

Information regarding online access to British Standards via British Standards Online can be found at www.bsigroup.com/BSOL

Further information about BSI is available on the BSI website at www.bsigroup.com/standards

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. This does not preclude the free use, in the course of implementing the standard of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained. Details and advice can be obtained from the Copyright & Licensing Manager.

Tel: +44 (0)20 8996 7070

Email: copyright@bsigroup.com

BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

Tel +44 (0)20 8996 9001

Fax +44 (0)20 8996 7001

www.bsigroup.com/standards

raising standards worldwide™

Copyright European Committee for Electrotechnical Standardization
Provided by IHS under license with CENELEC
No reproduction or networking permitted without license from IHS

Not for Resale

